



8 N I N

150 MIN

- 2. ALL JOINTS MORTARED TO BE SET WITH RUBBER GASKET.
- 3. MAXIMUM DISTANCE FROM RIM TO TOP RUNG IS 500 mm.
- 4. BACKFILL AROUND MANHOLE WITH SELECT NATIVE MATERIAL. COMPACT TO 98% SPD.
- 5. ALL JOINTS TO BE WATERTIGHT. METHODS TO BE CONSISTENT WITH SITE CONDITIONS.
- 6. FOR MANHOLES 5.0 m IN DEPTH OR GREATER, A SAFETY PLATFORM SHALL BE INSTALLED.
- 7. MANHOLES TO MEET REQUIREMENTS OF MANHOLE DETAILS AND SPECIFICATIONS.
- 8. SAFETY STEPS TO BE PROVIDED, SPACED AT 400 MAX. FIRST STEP 500 MAX. BELOW FRAME, LAST STEP 300 MAX. ABOVE BASE.

STANDARD MANHOLE DETAIL

Scale: NTS

